



RECEIVED  
JUL 20 2017

RAdata, Inc.  
27 Ironia Road, Unit 2  
Flanders, NJ 07836  
973-927-7303 Phone  
973-927-4980 Fax

Customer: Heidi Zaentz  
Monmouth Day Care Center BY: \_\_\_\_\_  
9 Drs. James Parker Boulevard  
Red Bank, NJ 077010000

# Laboratory Results

Sample Number	Sample Location	Collected By
0617-6611	9 Drs. James Parker Boulevard - Red B	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL <sup>#</sup>	Method
0617-6611	6/23/2017 6:01:00 AM Staff Bathroom Tap	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-1	6/23/2017 6:01:00 AM Staff Bathroom Tap	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-10	6/23/2017 6:05:00 AM Orange Room Right Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	2.35 ug/l	15 ug/L	Std Method 3113B
0617-6611-10	6/23/2017 6:05:00 AM Orange Room Right Sink	7/5/2017 11:27:00 AM	Copper	0.0550 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-11	6/23/2017 6:07:00 AM Yellow Room Bathroom Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	2.13 ug/l	15 ug/L	Std Method 3113B
0617-6611-11	6/23/2017 6:07:00 AM Yellow Room Bathroom Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-12	6/23/2017 6:10:00 AM Rainbow Room Left Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-12	6/23/2017 6:10:00 AM Rainbow Room Left Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-13	6/23/2017 6:12:00 AM Nurse Left Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	3.03 ug/l	15 ug/L	Std Method 3113B
0617-6611-13	6/23/2017 6:12:00 AM Nurse Left Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-14	6/23/2017 6:15:00 AM Kitchen Left Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-14	6/23/2017 6:15:00 AM Kitchen Left Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-2	6/23/2017 6:17:00 AM Kitchen Right Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-2	6/23/2017 6:17:00 AM Kitchen Right Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-3	6/23/2017 6:19:00 AM Kitchen Counter Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, July 20, 2017

NJDEP Laboratory Certification # 14006

Page 1 of 3



**RAdata, Inc.**  
**27 Ironia Road, Unit 2**  
**Flanders, NJ 07836**  
**973-927-7303 Phone**  
**973-927-4980 Fax**

**Customer:** Heidi Zaentz  
 Monmouth Day Care Center  
 9 Drs. James Parker Boulevard  
 Red Bank, NJ 077010000

## Laboratory Results

Sample Number	Sample Location	Collected By
0617-6611	9 Drs. James Parker Boulevard - Red B	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0617-6611-3	6/23/2017 6:19:00 AM Kitchen Counter Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-4	6/23/2017 6:21:00 AM Blue Room Right Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-4	6/23/2017 6:21:00 AM Blue Room Right Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-5	6/23/2017 6:23:00 AM Red Room Right Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-5	6/23/2017 6:23:00 AM Red Room Right Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-6	6/23/2017 6:25:00 AM Purple Room Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-6	6/23/2017 6:25:00 AM Purple Room Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-7	6/23/2017 6:27:00 AM Purple Room Left Bathroom Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-7	6/23/2017 6:27:00 AM Purple Room Left Bathroom Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-8	6/23/2017 6:30:00 AM Green Room Bathroom Sink	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-8	6/23/2017 6:30:00 AM Green Room Bathroom Sink	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0617-6611-9	6/23/2017 6:37:00 AM Staff Bathroom Sink Source	7/14/2017 8:29:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6611-9	6/23/2017 6:37:00 AM Staff Bathroom Sink Source	7/5/2017 11:27:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, July 20, 2017

NJDEP Laboratory Certification # 14006

Page 2 of 3



**RAdata, Inc.**  
 27 Ironia Road, Unit 2  
 Flanders, NJ 07836  
 973-927-7303 Phone  
 973-927-4980 Fax

**Customer:** Heidi Zaentz  
 Monmouth Day Care Center  
 9 Drs. James Parker Bouelvard  
 Red Bank, NJ 077010000

## Laboratory Results

Sample Number	Sample Location	Collected By
0617-6611	9 Drs. James Parker Bouelvard - Red B	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL <sup>#</sup>	Method
------------	-----------	----------	-----------	--------	------------------	--------

**The parameters tested on this report PASSED NJ Drinking Water Standards.**

*This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.*

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, July 20, 2017

NJDEP Laboratory Certification # 14006

Page 3 of 3